



PRITAM INDIA

Complete firefighting and safety solution



REF NO. PI/AGT/326/2026

DATE-28.07.2026

TO WHOM IT MAY CONCERN

This is to Certify That the Following Fire Extinguisher Were Checking/Testing/Refilling /Reconditioning/Servicing Done by Us at Your Site and Make+ Them Ready for Further Service

Party Name & Address : Golden valley H.S.(+2STAGE) SCHOOL
Dharmangar, Tripura
Vehicle No & Catagory :
Type Of Fire Extingulsher - : ABC S/P & co2 Type Fire Extingulsher
Quantity Of Fire Extingulsher : 04 (four) No's
Capacity Of Fire Extingulsher : ABC s/p 04 kg-02 no's, co2 02 kg-01 no, co2 4.5kg-01 no

Dry Chemical Powder Condition: ISI mark & good condition

Stored Pressure Condition :Dry n2 gas pressure "ok" conditlon

Co2 Weight :-

Date Of Checking : 29-07-2026

Date Of Refilling / Testing : 29-07-2026

Next Refilling Due On : 28-07-2027

FOR, PRITAM INDIA



AUTHORISED SIGNATORY

(Signature)
28/07/2026
(Date)

Principal

Golden Valley H. S. School
Tajbari, Dharmangar, (N) Tripura.
Affiliation No: 2020027
School Code- 37431

Address: L.N.Bari Road;
Opp Laxminarayan Temple
Agartala; West Tripura - 799 001

Contact: +91 9774129382 / 9840783807
Email: pritamindia.nag@gmail.com
<http://www.pritamindia.com>

GST No: 16AJEPN8088N1ZF
PAN No: AJEPN8088N